

KINCAID ♦ BRYANT

Consulting Engineers
A professional corporation

Mechanical ☒ Electrical ☒ Plumbing ☒ Fire Protection ☒ Value Engineering

P.O. Box 3476
Lynchburg, Virginia 24503

725 Church Street, 7th floor
Lynchburg, Virginia 24504

phone: 434-846-6510
fax: 434-846-0005

To: **All Document Holders**

From: **KINCAID ♦ BRYANT**

Date: **September 19, 2006**

Comm. No.: **04065**

Project: **SWVTC – Underground Heat Distribution System Replacement**
Project Code: 720-16975-000

RE: **Addendum No. 2**

Gentlemen:

Enclosed for your information is a copy of Addendum No. 2, including changes and modifications to the Specifications and Drawings, for the above referenced project.

Please attach this addendum to all copies of the Contract Documents in your possession so that they may be brought up-to-date.

Acknowledgment of receipt of this addendum is required on the Bid Form.

Sincerely,
KINCAID ♦ BRYANT



David A. Kincaid, PE

Enclosure

KINCAID ♦ BRYANT

Consulting Engineers

A professional corporation

Mechanical ☒ Electrical ☒ Plumbing ☒ Fire Protection ☒ Value Engineering

P.O. Box 3476
Lynchburg, Virginia 24503

725 Church Street, 7th floor
Lynchburg, Virginia 24504

phone: 434-846-6510
fax: 434-846-0005

To: **All Document Holders**

From: **KINCAID ♦ BRYANT**

Date: **September 19, 2006**

Comm. No.: **04065**

Project: **SWVTC – Underground Heat Distribution System Replacement**
Project Code: 720-16975-000

RE: **Addendum No. 2**

At the time of submission of bids, written acknowledgment of receipt of this Addendum by the Bidder shall be made in the appropriate blank on the Bid Form.

This Addendum has been issued to all Document Holders on record with our office. Bidders shall see that all Sub-Contractors are properly notified of the applicable provisions herein.

The information in this Addendum supersedes any contradictory information or omission set forth in the Contract Documents, including all previous addendums.

End of ADDENDUM NO. 2

03/20/2006 10:05 040665 RENEED BRYANT PAGE 00140

Addendum No. 2, dated September 19, 2006, to Bidding Documents for Southwestern Virginia Training Center – Hillsville, Virginia: Underground Heat Distribution System Replacement, Plans and Specifications dated August 15, 2006, K♦B File No. 04065, Project Code: 720-16975-000.

TO: PLAN HOLDERS OF RECORD

FROM: KINCAID ♦ BRYANT, Consulting Engineers
725 Church Street, 7th Floor
Allied Arts Building
Lynchburg, VA 24504

This Addendum forms a part of the Contract Documents and modifies the Plans and Specifications dated August 15, 2006, as noted below. Acknowledge receipt of this Addendum on the Bid Form. Failure to do so may subject Bidder to disqualification.

DRAWINGS

A9: Wall Section B and Detail 3 – Fascia board consists of a 34/"x1'-21/2" cedar plywood on pressure treated 2-2x8 #2 Y.P. blocking with 2x4 treated yellow pine blocking at the roof.

A10 and A11: Match existing pre-finished metal coping caps.

M18: Cottages No. 6 and 8 – Remove all existing supply and return ductwork and provide new exterior insulated sheet metal ductwork. Reuse existing registers and grilles. See Sketches SK-16 to SK-25.

M19: Cottages No. 6 and 8 – Remove all existing supply and return ductwork and provide new exterior insulated sheet metal ductwork. Reuse existing registers and grilles. See Sketches SK-4 to SK-15.

M20: Geothermal Piping In Trench Detail – Change detail as indicated in attached Sketch SK-3.

M24: Delete Pump Schedule – Continued and substitute the attached Sketches SK-1 and SK-2.

SPECIFICATIONS

Section 00310 – Bid Form: Delete and substitute the attached.

Section 02300 – Earthwork: Delete Paragraph 1.2.B.1.
Delete Paragraph 1.3.A.

Section 15732 – Packaged, Outdoor, Central-Station Air-Handling Units:
Delete and substitute with the attached Section 15732.

END OF ADDENDUM NO. 2